



Analogue Regulator for A1 port @ ROC

RIKEN/RBRC
Itaru Nakagawa

Input Voltage Anomaly for A1 Analogue Regulator





Voltage scan of the input/output voltage of analogue power regulators for FPHX at ROC



NW4







Circuit Design

Traced back circuit for the analogue regulator for A1 port in the ROC circuit drawing.













+2.5V V_{out} and AGND


Analogue



Digital




A1 port



Regulator	+2.5V_AX	AGND_X
U614	0	0
U615	1	1
U616	2	2
U617	3	3
U618	4	2
U619	5	5
U604	6	6
U605	7	7



AGND_2 is wired to U616 as well

AGND_2 Trace on ROC




DF11-20DP-20SA


Regulator for Column-A, Station-1



Calib-Multiplexer for Column-A




DF18 for Column-A, Station-0





Evidently, there is mis-match in the analogue GND. Station-0 and Station-1 are mixed.

AGND_6 Trace on ROC




DF11-200P-2DSA


J1A port
(FPHX Power for Station-1)



Calib-Multiplexer for Column-C




DF18 for Column-C Station-1



AGND is wired within Column-C, Station-1 throughout ROC trace as expected.


AGND_4 Trace on ROC




DF11-200P-2DSA

J1A port
(FPHX Power for Station-1)

No regulator is wired from AGND_4




Calib-Multiplexer for Column-B



DF18 for Column-A Station-1


The AGND_4 analogue ground is not wired to any regulators.

AGND_2 Trace on ROC




DF11-20DP-20SA



Regulator for Column-A, Station-1




Regulator for Column-A, Station-0



Calib-Multiplexer for Column-A





DF18 for Column-A, Station-0



AGND_2 is shared with Column-A, Station-0 and Station-1 analogue regulators.


Present Circuit Diagram



Presumably, the floating AGND also picks up some positive voltage with increasing V_{in} . As the consequence, the input relative voltage $V_{in} - V_{AGND}$ at the regulator becomes smaller than V_{in} . However, the voltage at FPHX recovers $\sim 2.8V$ because the AGND is provided by PS GND through DGND line.

Not sure how stable U618 regulator output is with this floating ground though

FVTX Case Circuit Diagram




AGND is provided by A0 power supply which is likely to be shared with the GND of A1 analogue power supply. This circuit effectively secures stable operation of U618 regulator presumably.



Not sure how stable U618 regulator output is with the floating ground with open J1 and DF18(P100,P101) for INTT case. It is not guaranteed INTT works as well as FVTX.


How can we recover?



Disable AGND_2 connection and Install new jumper cable.

Need to bridge between primary side and back side of the ROC boards. This is not trivial recovery. Keep searching for more portable solution.

Column-C1 Analogue Regulator Measurement




Interception Board


- Connected only J1A Channel 11,12
- Ladder + 40cm conversion cable on C1 port
- Voltage meas. at U604 & Interception Board
- Observed 0V for digital power at Interception Board

Interception Board & V_{out}

PS [V]	Current [A]	C1876 [V]	C1875 [V]	Intcpt Bd. [V]
1.5	0.00	1.5	0.8	0.8
2.0	0.05	1.9	1.8	1.8
2.5	0.07	2.3	2.2	2.2
3.0	0.09	2.9	2.8	2.8
3.5	0.09	3.2	2.8	2.8
4.0	0.09	3.8	2.8	2.8
4.5	0.09	4.5	2.8	2.8




Column-A1 Analogue Regulator Measurement



The output voltage at analogue regulator is 2.8V.
Observed +0.4V higher voltage at the interception board.
Presumably it is caused by the ground level difference.

PS [V]	Current [A]	C1920 [V]	C1919 [V]	Intcpt Bd. [V]
1.5	0.00	1.3	0.44	0.58
2.0	0.03	2.0	1.2	1.3
2.5	0.06	2.2	1.9	2.2
3.0	0.09	2.5	2.4	2.7
3.5	0.10	3.1	2.8	3.2
3.9	0.11	3.4	2.8	3.2
4.5	0.11	4.0	2.8	3.2

- Connected only J1A Channel 3,4
- Ladder + 40cm conversion cable on A1 port
- Voltage meas. at U618 & Interception Board
- Observed 0V for digital power at Interception Board




NE3 Analogue Power Trace Resistance

Only J1A Ch-3,4 cables are connected to PS




C1



Analogue GND Line is directly connected to AGND of Interception board

A1




Analogue GND Line is **not** directly connected to AGND of Interception board

NE3 Analogue Power Trace Resistance

A1


Interception Board



No ROC Power Cable Plugged in


A1

Interception Board




ROC Power Cable Plugged in, but not powered

NE3 Analogue Power Trace Resistance



ROC Power Cable Plugged in, Power On



ROC Power Cable Plugged in, but not powered