

# 260-L LAr System Progress Report

Yichen, Sergey, Steve

10/3/22



# Lab Safety and Space Management

- COVID level in Suffolk County is HIGH now
- Face masks are required onsite at BNL
- Please remember to wear the face mask when arriving at the gate
- Take the additional trainings required for all employee
  - ~~Ethics and Privacy by 9/2;~~
  - Active shooter training by 9/30
- My crane operation training renewed
- CRP coldbox ESR is still under review


# New LAr Heater Test

## ▶ LAr heater to accelerate the circulation

- Maximum power 735W with 120V AC—>Max. current is ~6.2 A
- 1/2" diameter with 6" length; Head to head weld to a 1/2 SS tube
- Wire leads mechanically crimped, no soldering; Tube volume sealed with plaster

## ▶ Heater test

- Water heating test with power supply with a AC variator with 0-140V AC output with current monitoring
  - The AC variator has a 10 Amp fuse, exceeding the heater rating
  - Current slight drops during water heating at constant AC power supply—>Resistance increases with temperature
  - Possible reason for heater broken: resistance drops in cryogenic temperature, overload with the same supply voltage:
  - Solutions: Limit the maximum voltage; Replace the 10 Amp with a 6 Amp fuse
- LN2 boiling test will be conducted next in an open mouth dewar





# Inline filter liquid sampling test

## ▶ Inline filter performance test with liquid

- Direct liquid sample at the outlet of inline filter when transferring LAr from one supply dewar to the other one
- Validate performance of inline filter with LAr without influence by the filling hose
- Plumbing completed, system leak check in progress
- Plan to conduct the measurement tomorrow




Gas Analyzers



# Oxygen Analyzer calibration

## ► Oxygen analyzer calibration with input pressure

- Moisture analyzer error message occasionally pop ups
- Analyzer stops data taking and disturb the flow/reading to the other analyzers
- It seems to associate with the onsite power dip
- Every time it can be solved with reset and INI file restoration
  - It works well since yesterday afternoon
- Will conduct the measurement after inline filter test
  - If the problem still exist, will stop the flow to the gas analyzer





# Improvement on pressure relief

## ► Change to a 2-stage pressure relief device in series

- To ensure the leak tightness
- Burst disk with metal seal to ensure no leaks
  - Potential vendor found with the product we need
- Relief valve for safety ensure no air exposure
  - Aleksey provides an inline check valve but not leak tight to our requirements
- Consulting with Mike Gaffney to get higher pressure rating

Burst disk



Relief valve



# Plan for the next run

## ▶ **Improvement on the inline filter**

- Change the location and devices for the pressure relief
- Change to the rupture disk+relief valve structure on the inline filter and the filling line

## ▶ **Improvement on the filling line**

- Replace the flexible hose to 1/2 SS tube for most part of plumbing
- Reserve only ~3-4 ft flex hose for installation flexibility with swagelok fittings
- Seal the drain valve on the main dewar with epoxy

## ▶ **Top flange improvement**

- Open-up the top flange and move it to the assembly stand
- Replace the broken heater tube
- Replace the differential level gauge
- Adding gas sampling tube
- Increase the size of liquid sampling tube