

Brookhaven National Laboratory
Collider Accelerator Dept


RHC Recovery review


ODH Analysis for SERVICE BLDGS

Ashish Shukla, Chintan Sheth, Roberto Than


Outline

- Analysis methodology
- Calculation Inputs
(Helium Inventory, Building info and components info)
- Normal operation/Unusual Events Initiator
- Components failure and release rate
- Results for different operating modes,
with and without ventilation
- Conclusion





GENERAL FAILURE TREE DIAGRAM



Probability Tree

Components inside Insulating vacuum vessel failing and leading to releasing via components failing on the insulating vacuum boundaries

Components inside Insulating vacuum vessel
18.6 bar & CCB event: e.g. 1E-5 ·


Σ Equipment Failure Rate

4 bar operation: 1-(1E-5)·

Σ Equipment Failure Rate

Components On Insulating vacuum vessel boundary

Equipment Failure Rate
 Man Cover:
 Hivacuum ports:
 [O-ring interfaces:]
 Leakage/Release



Helium Inventory in RHIC

- Sextant M-Line inventory: ≈ 3000 Gal $\approx 300,000$ SCF
- Building Volume: $\approx 60,000$ CF to $\approx 90,000$ CF
- Net Free Volume: $\approx 55,000$ CF to $\approx 85,000$ CF
- No fresh Air: O₂ \rightarrow 0%
- HVAC Fresh Air: Make-up \rightarrow 1800 to 3000 CFM
- ODH Sensing & Fans: Fresh Air Make-up \rightarrow 14,000 to 26,000 CFM
- Insulating Vacuum Volume Relief piped out of building
- Reliefs piped out of building
- Ruptures inside Insulating vacuum volume: Reliefs outside building
- Ruptures outside insulating vacuum volume into building

Valvebox Components:

Failure and Leakage to inside of building:1004B

Main Room
Volume = L x W x H = 465.5×1162.5×192 = 103,899,600 in³


Blue Area Volume = Total volume – Restroom = 24708192 in³

Total Volume = L x W x H = 465.5×294.5×192= 26321232 in³

Restroom only Volume = L x W x H = 71.5×117.5×192 = 1613040 in³


Restroom

	in ³	Ft ³
1004B Gross Volume	149,355,675	86,433
1004B Equipment Volume	7,298,002	4,223
1004B Net Volume	142,057,673	82,209




All References
Area 857726 in²
Volume 4579121 in³

All References
Area 1190906 in²
Volume 217961 in³




All References
Area 942060 in²
Volume 2500920 in³


All References
Area 599255 in²
Volume 127669 in³



1004B – Yellow Valve Box P&ID



Valve Stem & Valve bonnet




1600 Amp Current Lead

NOTES:


1. ALL WELDS TO BE VACUUM TIGHT, LEAK RATE NOT TO EXCEED 1×10^{-9} cc He/sec.
2. WELDS TO BE IN ACCORDANCE WITH ASME BOILER AND PRESSURE VESSEL CODE SECTION IX PART QW.
3. ARGON PURGE FOR THE DURATION OF ALL WELDING.
4. MARK IN ACCORDANCE WITH MIL-STD-130, ETCH PART NUMBER AND REV LETTER USING .15 HIGH CHARACTERS. LOCATE APPROX. AS SHOWN.

REVISIONS							
REV	ZONE	ECN NO.	DESCRIPTION	BY	DATE	CHK	APP
A			INITIAL RELEASE	AA	1/22/96	SN	MI
B	D	CR309	AS PER ECN	HRM	10/29/97	SN	AN



SEE SEPARATE PARTS LIST PL34045137


OUTSTANDING ECN NUMBERS	INTERPRET IN GENERAL ACCORDANCE WITH ASME Y14.24M-1989		BROOKHAVEN NATIONAL LABORATORY ASSOCIATED UNIVERSITIES, INC. UPTON, N.Y. 11973
	UNLESS OTHERWISE SPECIFIED	DESIGN BY: A. ARNO III 12/1/96	TITLE: POWER LEAD ASSY, TUBE VACUUM
	DIMENSIONS ARE IN INCHES	DESIGN APPROVAL: A. Nicoletti 1/11/96	SIZE: C
	DECIMAL TOLERANCES: X .06, XX .02, XXX .005	CHECKED BY: S. Norton 1/11/96	DRAWING NUMBER: 34045137
	ANGULAR TOLERANCE: ± 1°	ENGINEER APPROVAL: A. Nicoletti 1/11/96	REV: B
		SUPERVISOR APPROVAL: M. Iarocci 1/19/96	SA: T.R. Muller 1/22/96
		SA APPROVAL: R. Alforque 1/22/96	SA CATEGORY: A-3
125/ FINISH	BREAK SHARP EDGES MAX. 0.3 MIN. .01		SCALE: 1/1
			WEIGHT: NA
			SHEET 1 of 1





Spiral Leak
 Cross Sectional Area:
 $0.036'' \times 0.052'' = 0.00187 \text{in}^2$

150 Amp Current Lead

NOTES:
 1. BUILD IN ACCORDANCE WITH RHIC SPEC. NO., RHIC-CR-E-3404-0082.
 2. WELDS TO BE VACUUM TIGHT, LEAK RATE NOT TO EXCEED 10⁻⁵ M TO 14/400.
 3. APPLY ITEM 21 TO ITEM 1 APPROX AS SHOWN, BEFORE INSERTING ITEM 2 INTO ITEM 1.
 4. MARK IN ACCORDANCE WITH MIL-STD-135, AND TAG WITH PART NO. AND APPLICABLE REV LETTER.




Leak through ceramic break will see same amount of He flow as the Spiral Leak since they share the same flow path.




Spiral Leak
 Cross Sectional Area:
 $0.035'' \times 0.19'' = 0.00665 \text{ in}^2$

REV	DESCRIPTION	DATE
1	ISSUED FOR FAB	1/17/01
2	ISSUED FOR FAB	1/17/01
3	ISSUED FOR FAB	1/17/01
4	ISSUED FOR FAB	1/17/01
5	ISSUED FOR FAB	1/17/01
6	ISSUED FOR FAB	1/17/01
7	ISSUED FOR FAB	1/17/01
8	ISSUED FOR FAB	1/17/01
9	ISSUED FOR FAB	1/17/01
10	ISSUED FOR FAB	1/17/01
11	ISSUED FOR FAB	1/17/01
12	ISSUED FOR FAB	1/17/01
13	ISSUED FOR FAB	1/17/01
14	ISSUED FOR FAB	1/17/01
15	ISSUED FOR FAB	1/17/01
16	ISSUED FOR FAB	1/17/01
17	ISSUED FOR FAB	1/17/01
18	ISSUED FOR FAB	1/17/01
19	ISSUED FOR FAB	1/17/01
20	ISSUED FOR FAB	1/17/01
21	ISSUED FOR FAB	1/17/01
22	ISSUED FOR FAB	1/17/01
23	ISSUED FOR FAB	1/17/01
24	ISSUED FOR FAB	1/17/01
25	ISSUED FOR FAB	1/17/01
26	ISSUED FOR FAB	1/17/01
27	ISSUED FOR FAB	1/17/01
28	ISSUED FOR FAB	1/17/01
29	ISSUED FOR FAB	1/17/01
30	ISSUED FOR FAB	1/17/01



1600 Amp Current Lead



Flange Leak
Dia 1.786", Gap 0.002"
Leak Area 0.012 Inch²



6300 Amp Current Lead



Dia at Flange O-ring 1.86", Gap 0.002"

Leak Area 0.012 Inch²

Spiral leak area Inner: 0.125"X0.15
 Leak Area 0.019 Inch²

Spiral leak area Outer: 0.107"X0.12
 Leak Area 0.013 Inch²


Bayonet, Capped {S-Line}

Limited by isolation valve: cryogenic valve seat failure.

Bayonet O-ring seal

Bayonet capped Trapped volume $\frac{1}{4}$ " relief @250 psig

Series: **Double failure to release**



Flanges {Relief pipe}

Dia 2.1" Gap 0.002"

Relief Area 0.0132 Inch²



Manway port cover

- Man cover diameter 44.5"
- Assumed 16 Ruptures of 0.08" along the perimeter of the O-ring
- Total leak area 0.315 Inch²






Bellow Rupture is result of sputtering.

Bello hole is measured and found to be 0.5×0.25 Inch²

Normal event and unusual events process parameters

	Conditions during failure events under Normal Operational Mode branch		Conditions during failure events under Unusual Initiator Mode branch	
Process circuit	Normal Pressure (Bar)	Normal Temperature (K)	Event Pressure (Bar)	Event Temperature (K)
M Line	4	4.8	18.6	10
H Line	15	45	18.6	56
S Line	3.5	4.8	18.6	10
U Line	1.3	4.8	18.6	10
R Line	1.3	4.8	18.6	10


Normal event and unusual events leak rates



Line	Components	Leak Area Inch ²	Molar Flow Release Rate	
			Normal operation event	Unusual initiator event
M Line			SCFM	SCFM
	Valve stem seal Leak 0.5" dia and 0.002" gap	3.14E-03	135.3	210.1
	Valve Bonnet Flange leak, 2.5" dia with 0.002: gap	1.57E-02	676.4	1050.7
	150 Lead Ceramic/SS304Cap Rupture	6.65E-03	286.4	444.8
	12x150 Lead helium line rupture	6.65E-03	286.4	444.8
	1600A Lead Leak: Flange Interface Norel/G10 Insulator	1.80E-03	77.5	120.4
	1600A Lead Flange o-ring failure: Flange gap: 0.002" x 2.5 inch diameter (3.38"Flange), oring dia 1.786	1.12E-02	483.2	750.7
	1600A Lead: Helium lead cooling return tube rupture: 3/8"OD x 0.035"WT	1.80E-03	77.5	120.4
	6300A Lead Leak: Norel/G10 Insulator flange	1.88E-02	807.4	1254.2
	6300A Lead Flange o-ring failure: Flange gap: 0.002" x 2.5 inch diameter (3.38"Flange) oring dia 1.86	1.17E-02	503.2	781.8
	6300A Lead: Helium lead cooling return tube rupture: 3/8"OD x 0.035"WT	1.32E-02	568.4	883.0
	Relief valve flange connection	1.32E-02	568.2	882.6
	1/4" Tube Instrument Line	1.57E-03	67.6	105.1
Ball Valve	3.14E-03	135.3	210.1	
H Line	Valve stem seal	3.14E-03	59.8	66.3
	Valve Bonnet	1.57E-02	298.8	331.3
	Relief valve flange connection	1.32E-02	251.0	278.3
	1/4" Tube Instrument Line	1.57E-03	29.9	33.1
	Ball Valve	3.14E-03	59.8	66.3
S Line	Valve stem seal	3.14E-03	120.6	210.1
	Valve Bonnet	1.57E-02	602.8	1050.7
	Capped Bayonet (0.75"NPS) with small 250 psig relief	4.71E-03	180.9	315.2
	Relief valve flange connection	1.32E-02	506.4	882.6
	1/4" Tube Instrument Line	1.57E-03	60.3	105.1
	Ball Valve	3.14E-03	120.6	210.1
U Line	Valve stem seal	3.14E-03	15.4	210.1
	Valve Bonnet	1.57E-02	77.2	1050.7
	Relief valve flange connection	1.32E-02	64.8	882.6
	1/4" Tube Instrument Line	1.57E-03	7.7	105.1
	Ball Valve	3.14E-03	15.4	210.1
R Line	Valve stem seal	3.14E-03	15.4	210.1
	Valve Bonnet	1.57E-02	77.2	1050.7
	Relief valve flange connection	1.32E-02	64.8	882.6
	1/4" Tube Instrument Line	1.57E-03	7.7	105.1
	Ball Valve	3.14E-03	15.4	210.1
INSULATING VESSEL			SCFM	SCFM
	Mancover+Bellow	0.44	1769	1769
	HiVacuum Pumpout Port: Turbo and vacuum gages ports	0.057	227.4	227.4

Probability of failure of vacuum insulation

# of Components	200
Failure Probability	1.00E-09
SC bus short probability	5.00E-05
Event Probability	5.02E-05



ODH Classifications

- Fatality Rate less than $< 10^{-7}$ /hr
- O2 Concentration $\geq 14\%$
- ODH 0: Posting & training

Based on the ODH Classification, the Department Chair /Division Manager or designee establishes and maintains the minimum controls required as follows:

ODH Classification	Controls
0	Postings Training
1	Postings Training (including practical demonstration of personal protective equipment [PPE]) PPE: <ul style="list-style-type: none"> • Personal Oxygen Monitor • Self-Rescue Respirator (Supplied Atmosphere)

Step 1 Based on the minimum oxygen concentration, the Department Chair /Division Manager or designee establishes and maintains the minimum controls required as follows:

Oxygen Concentration	Controls
$\geq 14\%$	Controls Required by ODH Classification (step 2).
$\geq 10\% < 14\%$	Controls Required by ODH Classification (step 2) plus ODH Monitoring (either fixed area or POM) that alarms locally.
$< 10\%$	Controls Required by ODH Classification (step 2) plus ODH Monitoring that provides alarms/indication both locally and before entering the area.

Alarms must be perceptible in the environment used (e.g., visual or vibration in high noise areas).

Note: Ensure to incorporate the impact from added monitoring to the ODH Classification process.

Fatalities / Hr.	ODH Classification
10⁻⁹ (i.e., Oxygen concentration not less than 18%)	No Classification Required
>0 but $<10^{-7}$ (Note 1)	0
$\geq 10^{-7}$ but $<10^{-5}$	1
$\geq 10^{-5}$ but $<10^{-3}$	2
$\geq 10^{-3}$ but $<10^{-1}$	3
$\geq 10^{-1}$	4

4.5K case, 1 ODH fan is working at 80% capacity

Building	Gross [Feet ³]	Equipment [Feet ³]	Net [Feet ³]	ODH capacity for 2 Fan 0.8 capacity	Leak rate SCFM	Min O2 level	Fatality rate	ODH class
1004B	86433	13309	73124	12264	1769.0	18.0%	7.75E-10	0
1006B	71176	2280	68896	13040	1769.0	18.2%	1.08E-09	0
1008B	57843	3345	54498	12960	1769.0	18.1%	7.02E-10	0
1010A	85877	4885	80991	8144	1769.0	16.4%	8.25E-10	0
1012A	86128	2614	83514	7608	1769.0	16.1%	8.09E-10	0
1002B	74362	3310	71052	10312	1769.0	17.4%	7.04E-10	0

1004B transient for 1 ODH fan

CASE: HELIUM MODE


FAN CAPACITY: 12264 CFM

4.5K case, Service buildings

BUILDING VOLUME: 73123.8704537037 CF

Fan triggers at: 19.5% Concentration 3 minute ramp duration

Minimum O2 concentration: 17.97 %



1006B transient for 1 ODH fan


CASE: HELIUM MODE FAN CAPACITY: 13040 CFM
 BUILDING VOLUME: 68895.973680555 CF

4.5K case, Service buildings

Fan triggers at: 19.5% Concentration 3 minute ramp duration

DISCHARGE FLOW 1769 SCFM


Minimum O2 concentration: 18.15 %



1008B transient for 1 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 12960 CFM
 BUILDING VOLUME: 54498.187977037 CF

4.5K case, Service buildings
 Fan triggers at: 19.5% Concentration 3 minute ramp duration




1010A transient for 1 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 8144 CFM
 BUILDING VOLUME: 80991.1626435185 CF

4.5K case, Service buildings

Fan triggers at: 19.5% Concentration 3 minute ramp duration




1012A transient for 1 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 7608 CFM
 BUILDING VOLUME: 83514.477349537 CF

4.5K case, Service buildings

Fan triggers at: 19.5% Concentration 3 minute ramp duration




1002B transient for 1 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 10312 CFM
 BUILDING VOLUME: 71051.77321875 CF

4.5K case, Service buildings

Fan triggers at: 19.5% Concentration 3 minute ramp duration




4.5K case, 2 ODH fans are working at 80% capacity

Building	Gross [Feet ³]	Equipment [Feet ³]	Net [Feet ³]	ODH capacity for 2 Fan 0.8 capacity	Leak rate SCFM	Min O2 level	Fatality rate	ODH class
1004B	86433	13309	73124	24528	1769.0	18.9%	7.74E-10	0
1006B	71176	2280	68896	26080	1769.0	18.9%	1.08E-09	0
1008B	57843	3345	54498	25920	1769.0	18.7%	7.02E-10	0
1010A	85877	4885	80991	16288	1769.0	18.7%	8.03E-10	0
1012A	86128	2614	83514	15216	1769.0	18.6%	7.90E-10	0
1002B	74362	3310	71052	20624	1769.0	18.9%	7.02E-10	0
Auxiliary Buildings with 1 ODH fan								
1004E	3000	20	2980	3000	128	9.0%	1.0E-8	0
1010Mez	10500	1200	9300	--	128	0%	2.0E-8	0


1004B transient for 2 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 24528 CFM **4.5K case, Service buildings** Fan triggers at: 19.5% Concentration 3 minute ramp duration
 BUILDING VOLUME: 73123.8704537037 CF DISCHARGE FLOW 1769 SCFM




1006B transient for 2 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 26080 CFM **4.5K case, Service buildings** Fan triggers at: 19.5% Concentration 3 minute ramp duration
 BUILDING VOLUME: 68895.9736805555 CF DISCHARGE FLOW 1769 SCFM




1008B transient for 2 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 25920 CFM **4.5K case, Service buildings** Fan triggers at: 19.5% Concentration 3 minute ramp duration
 BUILDING VOLUME: 54498.187977037 CF DISCHARGE FLOW 1769 SCFM




1010A transient for 2 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 16288 CFM **4.5K case, Service buildings** Fan triggers at: 19.5% Concentration 3 minute ramp duration
 BUILDING VOLUME: 80991.1626435185 CF DISCHARGE FLOW 1769 SCFM



1012A transient for 2 ODH fan


CASE: HELIUM MODE FAN CAPACITY: 15216 CFM **4.5K case, Service buildings** Fan triggers at: 19.5% Concentration 3 minute ramp duration
 BUILDING VOLUME: 83514.477349537 CF DISCHARGE FLOW 1769 SCFM



1002B transient for 2 ODH fan

CASE: HELIUM MODE FAN CAPACITY: 20624 CFM
 BUILDING VOLUME: 71051.77321875 CF

4.5K case, Service buildings Fan triggers at: 19.5% Concentration 3 minute ramp duration
 DISCHARGE FLOW 1769 SCFM




4.5K case, Fatality rate without HVAC and ODH


Building	Gross [Feet ³]	Equipment [Feet ³]	Net [Feet ³]	Min O2 level	Fatality rate	ODH class
1004B	86433	13309	73124	0	6.34E-04	2
1006B	71176	2280	68896	0	8.81E-04	2
1008B	57843	3345	54498	0	5.75E-04	2
1010A	85877	4885	80991	0	6.57E-04	2
1012A	86128	2614	83514	0	6.47E-04	2
1002B	74362	3310	71052	0	5.75E-04	2
Auxiliary Buildings for largest leak						
1004E	3000	20	2980	0	1.3E-8	0
1010Mez	10500	1200	9300	0	2E-8	0

O2 concentration without HVAC and ODH fan

Mancover+Bellow



O2 concentration without HVAC and ODH fan




For 285K scrub mode

Building	Gross [Feet ³]	Equipment [Feet ³]	Net [Feet ³]	Min O2 level	Fatality rate	ODH class
1004B	86433	13309	73124	15.6%	1.7E-10	0
1006B	71176	2280	68896	15.3%	3.9E-10	0
1008B	57843	3345	54498	14.1%	2.1E-09	0
1010A	85877	4885	80991	16.1%	8.1E-11	0
1012A	86128	2614	83514	16.2%	6.5E-11	0
1002B	74362	3310	71052	15.5%	2.0E-10	0
Auxiliary Buildings for largest leak						
1004E	3000	20	2980	0.02%	1.3E-8	0
1010Mez	10500	1200	9300	1.86%	2E-8	0

For 285K scrub mode


For largest leak in service building during scrub 285K



Maximum leak rate is
23.7 SCFM
Total inventory 21,000
CF.



For Auxiliary building

For largest leak in auxiliary building during scrub 285K



Maximum leak rate is
25.6 SCFM
Total inventory 21,000
CF.

40 K cooldown mode ODH Results



Conclusion

- ODH evaluation has been re-done for the Service Buildings
- The service buildings require credited controls of ODH sensing & Ventilation to get ODH 0 classification for 45K cooldown mode and 4.5K Normal operational mode and room temperature scrub.
- The auxiliary buildings require credited controls of ODH sensing & Ventilation to get ODH 0 classification for 45K cooldown mode and 4.5K Normal operational mode.
- During Room temperature scrub service buildings and auxiliary buildings falls in category of ODH 0 but O₂ concentration is between 16% to 0%.

Thank you

Backup slides

The oxygen concentration in the building during a release of a gas is approximated by solving the following differential equations:

$$\frac{dC}{d\tau} = \frac{O_{2_in} - O_{2_out}}{V}$$

$$\frac{dC}{d\tau} = \frac{0.21 \cdot Q_{in} - C \cdot Q_{out}}{V} = \frac{0.21 \cdot Q_{in}}{V} - \frac{C \cdot Q_{out}}{V}$$

Where
V = building volume (CF)
C = oxygen concentration (mole fraction)
t = time (minutes)
Q _{out} = the flow rate out of building
Q _{in} = the flow rate into building of fresh air
Q = exhaust fan(s) flow rate (CFM)
R = inert gas spill rate into building (CFM)

When fans are drawing from the volume.
Q _{out} = Q
Q _{in} = Q-R
For the case where R>Q the effective Q _{in} becomes zero and the Q _{out} becomes R
When fans are blowing into the volume.
Q _{in} = Q
Q _{out} = Q+R

Substituting for Q_{in} and Q_{out} using Q and R one can come up with the following equations.

Minimum Oxygen concentration without ventilation

This assumes the air gets displaced by the release gas, with the resulting remaining air mixing with the released gas resulting in the calculated concentration.

$$C_{\min_no_ventilation} = 0.21 \frac{V - R}{V}$$

CASE 1 Ventilation fan(s) blowing into the confined volume.

$$V \frac{dC}{d\tau} = 0.21Q - (R + Q)C$$

$$C(\tau)_{case_1} = \frac{0.21}{Q + R} \left[Q + R \cdot e^{-\frac{(Q+R)\tau}{V}} \right]$$

CASE 2 Ventilation fan(s) drawing and the spill rate of inert gas (R) is less than the exhaust fan capacity (Q):

$$V \frac{dC}{d\tau} = 0.21(Q - R) - QC$$

$$C(\tau)_{case_2} = 0.21 \left[1 - \frac{R}{Q} \cdot \left(1 - e^{-\frac{Q\tau}{V}} \right) \right]$$

CASE 3 If the exhaust fan is off or if the inert gas spill rate (R) is greater than the exhaust fan capacity (Q)

$$V \frac{dC}{d\tau} = -RC$$

$$C(\tau)_{case_2} = 0.21 \cdot e^{-\frac{R\tau}{V}}$$

Isentropic

DIM involves evaluating thermodynamic properties of the relieving stream at a number of state points and then numerically integrating the nozzle equation to determine the maximum mass flux

$$G^2 = -2\rho_i^2 \int_{p_0}^p v dp$$

$$\int_{p_i}^{p_{i+1}} v dp = \frac{(v_{i+1} + v_i)}{2} * (p_{i+1} - p_i)$$

Auxiliary Buildings

Auxiliary Buildings with 1 ODH fan								
Location	Volume	Equipment	Net Free Volume	Fan SCFM	Release Flow SCFM	O2 Concentration	Fatality rate 1/hr	ODH class
1004E	3000	20	2980	3000	128	9.0%	1.0E-8	0
1002A	22500	--	22500	3000	230	16.9%	9.0E-12	0
1010Mez	10500	1200	9300	--	128	0%	2.0E-8	0

Auxiliary Buildings							
Location	Volume	Equipment	Net Free Volume	Failure rate 1/hr	O2 Concentration	Fatality rate 1/hr	ODH class
1004E	3000	20	2980	1.3E-8	0%		0
1002A	22500	--	22500	3E-8	0%		0
1010Mez	10500	1200	9300	2E-8	0%		0