

Brookhaven National Laboratory Collider Accelerator Dept

7.09.2024

RHIC TIME MEETING CRYOGENICS

R Feder, R Than

- Central Cryo plant has been running well
- 7/7 to 7/8: 11Q14 lead flow thermistor repaired
- 7/2: AGS Cold Snake filled maintenance, system stable
- On-going VODH system collaboration

