

- RHIC Central Plant has been generally running well
- CEC 112 MHz
  - warmup and degas going well. Ion pumps back on in the 2E-9 Torr range
  - cooldown start planned for Wednesday morning. 4K Fill complete for Thursday.
- AGS cold snake added a bit of inventory during last maintenance day and the next day.

