

ePIC pfRICH Aerogel QA Progress Report


Matt Posik
Temple University

❑ Current aerogel tiles from Aerogel Factory

Type	TSA1.04	TSA1.04	TSA1.04
Serial number	TSA114-3	TSA120-1	TSA120-2
Refractive index (at 405 nm)	1.0377	1.0404	1.0401
Transmission length (at 400 nm) [mm]	51.2	48.9	49.3
Transmittance (at 400 nm) [%]	61.2	60.6	60.5
Lateral tile size (nominal) [mm]	109.9	109.4	110.4
Thickness (nominal) [mm]	25.1	24.5	24.8
Weight [g]	42.79	42.21	43.12
Density [g/cm ³]	0.141	0.144	0.143
Appearance	Slight damages	Good	Good
File name of transmittance data [.txt]	tsa114-3_2023.12	tsa120-1	tsa120-2

Tile	TU Measured
TSA88-1	Yes
TSA120-1	Yes
TSA120-2	Yes
TSA114-3	Yes

- Beam spot at Aerogel:
 - 3mm
- Beam spot at integrating sphere:
 - 10mm
- Distance from aerogel to integrating sphere
 - 12 cm



- Currently using 3 fixed wavelength LEDs are used



to measure the transmittance




(430nm, 530nm, 625nm)

- LED Measurement point


- Cut window to remove tails where intensity is too low
- Window sensitivity less than $\sim 0.2\%$

Example






Transmittance for single aerogel location




Transmittance averaged over aerogel area




Each LED wavelength has its own aerogel area map

$\langle \lambda \rangle = 520 \text{ nm}$

□ TSA88-1




□ TSA120-1




□ TSA120-2


$\langle \lambda \rangle = 432 \text{ nm}$



$\langle \lambda \rangle = 520 \text{ nm}$




$\langle \lambda \rangle = 634 \text{ nm}$




□ TSA114-3


$\langle \lambda \rangle = 432 \text{ nm}$







$\langle \lambda \rangle = 520 \text{ nm}$




$\langle \lambda \rangle = 634 \text{ nm}$




TU Transmittance Results








- ❑ Not able to scan entire tile at BNL → compartment too small
- ❑ 6 measurement spots per tile
 - 3 near top
 - 3 near bottom (flip tile upside-down)






Example: TU tile scan

☐ Good agreement seen between TU and BNL Transmittance values for all three tiles



☐ Good agreement seen between TU and BNL Transmittance values for all three tiles




	λ [nm]	TU T[%]	BNL T[%]	(TU-BNL)/BNL [%]
TSA120-1	432.4	67.83	67.01	1.22
	520.5	83.19	83.17	0.02
	633.7	92.33	91.95	0.41

	λ [nm]	TU T[%]	BNL T[%]	(TU-BNL)/BNL [%]
TSA120-2	432.4	67.17	66.84	0.49
	520.5	82.91	82.68	0.28
	633.7	91.71	91.35	0.39



	λ [nm]	TU T[%]	BNL T[%]	(TU-BNL)/BNL [%]
TSA114-3	432.4	69.35	68.79	0.81
	520.5	84.12	84.08	0.05
	633.7	92.69	92.44	0.27

Comparison of TU (average of four corners) and Aerogel Factory index of refraction measurements



Tile	TU ($\lambda = 403 \text{ nm}$)	AF ($\lambda = 405 \text{ nm}$)	(TU-AF)/AF [%]
TSA88-1	1.0398 +/- 0.0007	1.0390	0.077
TSA120-1	1.0413 +/- 0.0011	1.0404	0.087
TSA120-2	1.0401 +/- 0.0025	1.0401	0.000
TSA114-3	1.0383 +/- 0.0026	1.0377	0.062

Distance is the distance from light exiting the aerogel to the input port of the integrating sphere



☐ Transmittance Setup

- TU measurements of aerogel tiles consistent with those measured at BNL
 - Measurements validated!
- Add additional LED (340 nm) to increase number of measurement points to 4
 - Investigate fit to TU measurements to determine QA parameters

☐ Investigate new method of assessing index of refraction

- Aerogel tiles will be cut with water jet → non-optical quality edges

☐ Reassess frames used for aerogel handling

- Noticed some damage around tile edges due to frames