


SVT Power Estimates and Cooling Design

Ernst Sichtermann (LBNL)

Based on the work by many! Errors my own.


ePIC Collaboration Meeting
Brookhaven National Laboratory
January 21, 2026
Electron-Ion Collider



Outline

- Introduction
- Power dissipation
- Cooling
 - Air cooling of sensitive layers, disks
 - Humidity management
 - Liquid cooling of RDOs
- Summary

Silicon Vertex Tracker – SVT



- SVT is the innermost subsystem of the ePIC central detector,
- Most or all of us will have seen various visualizations, but as a reminder:
 - **Barrel**
 - **Inner Barrel (L0, L1, L2 Layers):** Curved, thinned, wafer-scale ITS3 sensors, called MOSAIX
 - **Outer Barrel (L3-L4 Layers):** based on EIC Large Area Sensor (LAS), which is derived from MOSAIX with a focus on large-area coverage in layers and disks (formfactor, yield, etc.)
 - **Endcap**
 - 5 Hadron Disk (HD0-4) and 5 Lepton Disks (ED0-4) with EIC-LAS Sensors
 - Overall dimensions $r \sim 0.4$ m, $l \sim 2.2$ m.

Outer Barrel and Disks – Schematic Layout

ePIC SVT - disk and barrel power and readout architecture

Sichtermann, Glover, Silber

| Rev | Date | Author | Description |
|-----|------------|-------------------|---|
| v1 | 2025-10-09 | Joe Silber (LBNL) | imported original diagram from Ernst , added details on sizes, counts, and connection interfaces |
| v2 | 2025-10-15 | Joe Silber (LBNL) | visual cleanup, approx dims on furcation tubes, power wire pairs, and CB-FIB ribbon |
| v3 | 2025-10-16 | Joe Silber (LBNL) | incorporated comments from Nikki on barrel vs disk variations; made MFPC and bridge connections more visually clear |
| v4 | 2025-12-16 | Joe Silber (LBNL) | Added ref links |
| | | | |
| | | | |

Nomenclature


FPC ... Flexible Printed Circuit
 CB ... Control Board
 FIB ... FPC Interface Board
 LV ... Low Voltage
 MFPC ... Main FPC
 BFPC ... Bridge FPC
 SPTab... bonded overlapping Al/Kapton

Notes

1. Not to scale.
2. Color-coding consistency not guaranteed.

References

1. [Live editable version of this document](#)
2. [module drawing from Nikki 2025-08-22](#)




Power dissipators in envelope: **sensor** and ancillary ASIC, FPCs (resistive), FIBs (VTRx+), FIB-CBs.

Electron-Ion Collider

Inner Barrel – Schematic Layout

IB Connections

NA - Version 2, 11/5/25



DPB: Detector Power Board

SCB: Segment Control Board

SIB: Segment Interface Board

Fiber harness: up to 144 fibers

Power and Cooling

- Power dissipation driven by the sensor(s),
- Sensors continue to be developed,
- We know quite a bit and use up-to-date insights with conservative assumptions, but power dissipation is not and cannot now be final.

Power Analysis Overview

❑ Actual case (160MHz): Revised estimates

• EIC-LAS: Total Power

- The most recent revised power estimates show a 1.3x improvement.
- Applying a slower clock (40MHz) to the tiles could significantly reduce power dissipation (further analysis ongoing).

| Supply | Voltage | RSU Power (mW) | LEC Power (mW) | EIC-LAS Power (mW) | RSU Power (mW) | LEC Power (mW) | EIC-LAS Power (mW) |
|----------------|---------|----------------|----------------|--------------------|----------------|----------------|--------------------|
| GAVDD | 1,32 | 36,96 | 0 | 221,76 | 59,4 | 0 | 356,4 |
| GDVDD | 1,32 | 106,932 | 68,805 | 710,397 | 145,086 | 81,246 | 951,762 |
| GSVDD | 1,32 | 2,112 | 25,08 | 37,752 | 3,168 | 35,772 | 54,78 |
| TXVDD | 1,2 | 0 | 66 | 66 | 0 | 91,2 | 91,2 |
| Total Power | | 146,004 | 159,885 | 1035,909 | 1454,142 | | |
| AncASIC (+35%) | | | | 1398,47715 | 1963,0917 | | |
| AncASIC (+45%) | | | | 1502,06805 | 2108,5059 | | |

TYP: 1.3x improvement MAX: 1.2x improvement

| | | | | |
|----------------|---------|--------|-----------|----------|
| Total Power | 168,432 | 371,76 | 1382,352 | 1791,18 |
| AncASIC (+35%) | | | 1866,1752 | 2418,093 |
| AncASIC (+45%) | | | 2004,4104 | 2597,211 |

Conservative values
currently in use

[ePIC SVT DSC meeting \(Sept 2025\)](#)

Electron-Ion Collider
ePIC SVT PDR2, January 27 and 28, 2026


João de Melo

20


Power and Cooling

- Air cooling of sensitive areas,
 - Required for innermost barrel and disk layers to meet resolutions,
 - Uniformity of design,
- Liquid cooling of RDOs – grouped layout,
- 5.9 (9.3) kW – typical (max) dissipation of sensors, ancillary ASIC, FPCs
- 1.2 kW – RDOs

| | Total air-cooled power/system [W] | |
|------------------|-----------------------------------|------|
| | typical | max |
| L0 | 30 | 37 |
| L1 | 40 | 50 |
| L2 | 101 | 124 |
| L3 | 514 | 776 |
| L4 | 1545 | 2442 |
| Disks | 3670 | 5819 |
| Total power [kW] | 5.90 | 9.25 |



Cooling – geometrical air volumes



Cooling – Schematic layout air cooling

ePIC SVT - cooling system diagram

| Rev | Date | Author | Description |
|-----|------------|-------------------|----------------------------------|
| v1 | 2025-12-11 | Joe Silber (LBNL) | initial release |
| v2 | 2025-12-12 | Joe Silber (LBNL) | add liquid system |
| v3 | 2025-12-16 | Joe Silber (LBNL) | space out e-/hadron & top/bottom |
| | | | |
| | | | |
| | | | |
| | | | |


Nomenclature

SVT ... Silicon Vertex Tracker
TBD ... To Be Determined
L# ... Barrel layer IDs
D# ... Disk IDs
V# ... Disk interstitial volume IDs
LV# ... Barrel layer interstitial volume IDs
SCB ... Segment Control Board
CB ... Control Board

Notes

1. Graphical elements not intended to follow any standard.
2. Color-coding consistency not guaranteed.

Link:
[ePIC SVT cooling system diagram - v3.pdf](#)



Cooling – Approach

High level requirements


Table 9.2: SVT component temperature requirements (N/S is not specified).

| Requirement | LEC | RSU | REC | AncASIC |
|----------------------------|-----|------------------------------------|-----|---------|
| Maximum T [°C] | 65 | 40 | N/S | 80 |
| Maximum T variation [°C] | 10 | 1 over 3 mm 10 over full length | N/S | 10 |


Req't on
 T_{max}

informs ΔT , ΔP ,
air speed


CAD design



Local supports heat transfer analysis



Local supports physical test




Electron-Ion Collider

End-to-end system performance calculation

| source --> | branches to hadron + electron sides | | branches to top + bottom halves | | pipes into ePIC to half barrels | | pipes within SVT to half barrels | | exhaust ducts |
|---|---|----------|---------------------------------|----------|---------------------------------|----------------|----------------------------------|----------------|---------------|
| ePIC | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 |
| stage description | - | - | - | - | - | - | - | - | - |
| stage index | - | - | - | - | - | - | - | - | - |
| num channels (per parent channel) | - | - | - | - | - | - | - | - | - |
| total num channels in system | n | 1 | 2 | 2 | 8 | 1 | 1 | 22.2 | 0.0169 |
| mass flow per channel | m | 0.950 | 0.475 | 0.238 | 0.030 | 0.030 | 0.030 | 0.079 | 0.079 |
| length | m | 10.000 | 10.000 | 15.000 | 7.000 | 3.000 | 0.000 | 0.001 | 0.001 |
| hydraulic diameter (mm) | mm | 100 | 75 | 50 | 23 | 23 | 23 | 11.5 | 713.8 |
| hydraulic diameter | mm | 0.100 | 0.075 | 0.050 | 0.023 | 0.023 | 0.023 | 0.012 | 0.062 |
| single channel cross-sectional area along length L | m ² | 7.85E-03 | 4.42E-03 | 1.96E-03 | 4.15E-04 | 4.15E-04 | 4.15E-04 | 1.04E-04 | 4.00E-01 |
| all channels total cross-sectional area | m ² | 7.85E-03 | 8.84E-03 | 7.85E-03 | 1.33E-02 | 1.33E-02 | 7.40E-02 | 4.80E+00 | 3.58E-02 |
| single channel cross-sectional area along length L | cm ² | 78.5 | 88.4 | 78.5 | 133.0 | 133.0 | 73.9 | 48.024 | 357.6 |
| entrance temperature | T ₁ = T _s or previous stage T ₃ | 276.0 | 276.32 | 275.59 | 277.01 | 276.80 | 276.68 | 278.12 | 287.32 |
| entrance pressure | P ₁ = P _s or previous stage P ₃ | 2.8 | 3.2 | 2.4 | 3.9 | 3.7 | 3.5 | 5.0 | 14.4 |
| entrance density (ideal gas law) | kg/m ³ | 1.801 | 1.753 | 1.675 | 1.482 | 1.365 | 1.310 | 1.308 | 1.260 |
| entrance dynamic viscosity | Pa*s | 1.73E-05 | 1.73E-05 | 1.73E-05 | 1.73E-05 | 1.73E-05 | 1.73E-05 | 1.74E-05 | 1.78E-05 |
| Reynold's number | - | 6.99E+05 | 4.66E+05 | 3.50E+05 | 9.48E+04 | 9.48E+04 | 8.50E+03 | 7.91E+03 | 9.18E+04 |
| friction factor (Blasius) | - | 0.011 | 0.012 | 0.013 | 0.018 | 0.018 | 0.018 | 0.033 | 0.034 |
| friction pressure drop (Darcy-Weisbach) | Pa | 4.438 | -5.317 | -17.025 | -9.440 | -4.394 | -153 | -114 | -825 |
| downstream pressure | P ₂ = P ₁ + ΔP ₁₂ | 138,216 | 133,727 | 115,432 | 108,409 | 104,014 | 103,862 | 104,323 | 103,104 |
| ambient pressure in the downstream area of this stage | P _{local_ambient} | bar | 1.382 | 1.337 | 1.154 | 1.084 | 1.040 | 1.038 | 1.043 |
| downstream pressure relative to local ambient | description(P ₂ - P _{local_ambient}) | - | positive | positive | positive | approx neutral | approx neutral | approx neutral | positive |
| module power input to stream | W | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8943.9 | 0.0 |
| stream temperature rise due to external heat input | ΔT _{in} = Q _c * N / (n * D * c _p) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

System
architecture

System layout



Operational logic

Detailed specs on cooling plant

| ID | Category | Description | Name | Value (SI) | Units (SI) |
|----|-------------|--|---------------|------------------------|---|
| 00 | process air | temperature - nominal | T_nom | 3 °C | |
| 01 | output air | temperature - adjustment range - min | T_min | -5 °C | |
| 02 | output air | temperature - adjustment range - max | T_max | 30 °C | |
| 03 | output air | temperature - stability about setpoint | T_stability | ±2 °C | |
| 04 | output air | pressure dew point - max allowable | PDP_max_allow | -10 °C | |
| 05 | output air | pressure dew point - stability | PDP_stability | ±2 °C | |
| 06 | output air | pressure dew point - setpoint adjustment | PDP setpoint | | Pressure dew point shall be defined by the AQ_water |
| 07 | output air | pressure - nominal | P_nom | 0.44 bar (gauge) | |
| 08 | output air | pressure - adjustment range - min | P_min | 0.03 bar (gauge) | |
| 09 | output air | pressure - adjustment range - max | P_max | 0.75 bar (gauge) | |
| 10 | output air | pressure - stability about setpoint | P_stability | ±0.02 bar (gauge) | |
| 11 | output air | mass flow rate - nominal | m_nom | 1.0 kg/s | |
| 12 | output air | mass flow rate - adjustment range - min | m_min | 0.1 kg/s | |
| 13 | output air | mass flow rate - adjustment range - max | m_max | 1.5 kg/s | |
| 14 | output air | density - nominal | p_nom | 1.82 kg/m ³ | |
| 15 | output air | density - min | p_min | 1.0 kg/m ³ | |

Cooling – Air

Cooling system performance baseline

- source temperature = 2.8°C
- total mass flow = 0.95 kg/s
- total volume flow = 1135 cfm @ source pressure, 1604 cfm @ exhaust
- source pressure = 1.43 bar → 1.03 bar positive pressure @ exhaust
- channel/stave entrance temperature = 5.0°C
- channel/stave air speed = 10.0 m/s
- total power extracted = 8.9 kW
- SVT internal ambient temperature = 14.4°C

| | A | B | C | D | E | F | G | H | I | J | K | L |
|-----|---|--|-----------------------|--------------------|---|---------------------------------------|---|--|----------------|-----------------------------|------------------------------------|---------------|
| | | | | source --> ePIC | branches to hadron + electron sides | branches to top + bottom halves | pipes into ePIC to half disks and half barrels | pipes within SVT to half disks and half barrels | manifold | disk channels and staves | SVT internal ambient volumes | exhaust ducts |
| 150 | stage description | - | - | | | | | | | | | |
| 151 | stage index | - | - | | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 8 |
| 152 | num channels (per parent channel) | n_i | - | | 1 | 2 | 2 | 8 | 1 | 1 | 22.2 | 0.0169 |
| 153 | total num channels in system | $N_i = \text{product}(n_i)$ | m | | 1 | 2 | 4 | 32 | 32 | 32 | 710 | 12 |
| 154 | mass flow per channel | $m = (n_i \text{ or previous stage } m) / n_i$ | kg/s | 0.950 | 0.475 | 0.238 | 0.030 | 0.030 | 0.030 | 0.001 | 0.079 | 0.079 |
| 155 | length | L | m | 10.000 | 10.000 | 15.000 | 7.000 | 3.000 | 0.100 | 0.635 | 0.433 | 10.000 |
| 156 | hydraulic diameter (mm) | D_{mm} | mm | 100 | 75 | 50 | 23 | 23 | 23 | 11.5 | 713.8 | 61.6 |
| 158 | single channel cross-sectional area along length L | $A_{12} = \pi D^2 / 4$ | m^2 | 7.85E-03 | 4.42E-03 | 1.96E-03 | 4.15E-04 | 4.15E-04 | 4.15E-04 | 1.04E-04 | 4.00E-01 | 2.98E-03 |
| 160 | all channels total cross-sectional area | $\Sigma A_{12,i} = A_{12,i} * N_i$ | cm^2 | 78.5 | 88.4 | 78.5 | 133.0 | 133.0 | 133.0 | 739.6 | 48,024.7 | 357.6 |
| 162 | entrance temperature | $T_1 = T_s \text{ or previous stage } T_3$ | $^{\circ}\text{C}$ | 2.8 | 3.2 | 2.4 | 3.9 | 3.7 | 3.5 | 5.0 | 14.4 | 14.2 |
| 164 | entrance pressure | $P_1 = P_s \text{ or previous stage } P_3$ | bar | 1.427 | 1.390 | 1.325 | 1.178 | 1.084 | 1.040 | 1.044 | 1.043 | 1.039 |
| 167 | Reynold's number | $Re = 4 \bar{m} / (\pi D \mu_i)$ | - | 6.99E+05 | 4.66E+05 | 3.50E+05 | 9.48E+04 | 9.48E+04 | 9.48E+04 | 8.50E+03 | 7.91E+03 | 9.18E+04 |
| 169 | friction pressure drop (Darcy-Weisbach) | $\Delta P_{12} = f * (L/D) * \bar{m}^2 / (2 \rho_1 A_{12,i}^2)$ | Pa | -4.438 | -5,317 | -17,025 | -9,440 | -4,394 | -153 | -114 | 0 | -825 |
| 171 | downstream pressure | $P_2 = P_1 + \Delta P_{12}$ | bar | 1.382 | 1.337 | 1.154 | 1.084 | 1.040 | 1.039 | 1.043 | 1.043 | 1.043 |
| 172 | ambient pressure in the downstream area of this stage | $P_{\text{local_ambient}}$ | bar | 1.013 | 1.013 | 1.013 | 1.043 | 1.043 | 1.043 | 1.043 | 1.043 | 1.013 |
| 173 | downstream pressure relative to local ambient | description($P_2 - P_{\text{local_ambient}}$) | - | positive | positive | positive | positive | approx neutral | approx neutral | approx neutral | approx neutral | positive |
| 174 | module power input to stream | $Q = Q_c * N_i \text{ if channel or stave else } 0$ | W | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8943.9 | 0.0 | 0.0 |
| 175 | stream temperature rise due to external heat input | $\Delta T_{q12} = Q / (N_i * \bar{m} * c_p)$ | K | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 9.4 | 0.0 | 0.0 |
| 181 | downstream temperature | $T_2 = T_1 + \Delta T_{q12} + \Delta T_{K12}$ | $^{\circ}\text{C}$ | 2.7 | 3.0 | 1.6 | 3.7 | 3.5 | 3.5 | 14.3 | 14.4 | 14.2 |
| 185 | average volumetric flow | $V_a = \bar{m} / \rho_a$ | m^3/s | 0.536 | 0.276 | 0.151 | 0.021 | 0.022 | 0.023 | 0.001 | 0.063 | 0.063 |
| 187 | total volumetric flow (all channels) | $\Sigma V_a = V_a * N_i$ | m^3/s | 0.536 | 0.552 | 0.605 | 0.667 | 0.710 | 0.726 | 0.738 | 0.751 | 0.757 |
| 188 | " | " | cfm | 1134.9 | 1170.2 | 1282.8 | 1414.1 | 1505.3 | 1537.9 | 1564.8 | 1592.3 | 1603.5 |
| 189 | average air speed | $u_a = V_a / A_{12}$ | m/s | 68.2 | 62.5 | 77.1 | 50.2 | 53.4 | 54.6 | 10.0 | 0.2 | 21.2 |
| 194 | pressure ratio calculated with non-choked eqn | $\beta_{3n} = P_{3n} / P_2$ | - | 1.006 | 0.993 | 1.028 | 1.000 | 1.000 | 1.018 | 1.001 | 0.997 | 1.003 |
| 195 | is choked? | $\beta_{3n} < \beta_x$ | boolean | FALSE | FALSE | FALSE | FALSE | FALSE | FALSE | FALSE | FALSE | FALSE |
| 214 | system energy balance error | $\dot{E}_{\text{err}} = (\dot{E}_2 - \Sigma Q_i) - \dot{E}_{\text{1_stage0}}$ | W | -2 | -4 | -24 | -26 | -27 | -27 | -24 | -24 | -24 |
| 215 | system energy balance error fraction (w.r.t. total energy) | $\dot{E}_{\text{err_frac}} = \dot{E}_{\text{err}} / \dot{E}_{\text{1_stage0}}$ | - | -0.001% | -0.002% | -0.009% | -0.010% | -0.010% | -0.010% | -0.009% | -0.009% | -0.009% |
| 216 | system energy balance error fraction (w.r.t. total input pov) | $\dot{E}_{\text{err_frac}} = \dot{E}_{\text{err}} / \Sigma Q_i$ | - | -0.027% | -0.049% | -0.274% | -0.293% | -0.307% | -0.307% | -0.272% | -0.272% | -0.272% |


Cooling – Humidity management

- Humidity must be managed, since cooling air will usually be below the ambient dew point,

- Approach:

- Supply dried air, class 3 ISO 8573-1:2010 or better,
- Insulate exterior cold pipes,
- Interlock SVT operation and divert supply air if supply air conditions are not met, e.g. as the cooling system settles during startup,
- Interlock SVT operation if ambient conditions are not met, e.g. if WAH HVAC is not operational,
- Limit backflow and moisture effusion into SVT if air flow shuts down while interior structures are cold.

Dewpoint data May – August 2024, sPHENIX Hall – courtesy Dan Cacace



| | A | B | C | D | E | F | G | L |
|-----|---|---|----------|-------------------------------------|---------------------------------|--|---------------|------|
| | stage description | | source | branches to hadron + electron sides | branches to top + bottom halves | pipes into ePIC to half disks and half barrels | exhaust ducts | |
| 151 | stage index | - | ==> ePIC | 0 | 1 | 2 | 3 | 8 |
| 152 | num channels (per parent channel) | - | | 1 | 2 | 2 | 8 | 1 |
| 153 | total num channels in system | n _i | | | 2 | 4 | 32 | 12 |
| 154 | mass flow per channel | N _i = product(n _i) | m | 0.475 | 0.238 | 0.030 | 0.079 | |
| 155 | length | m = (m _i or previous stage m) / n _i | kg/s | | | | | |
| 156 | hydraulic diameter (mm) | L | m | 10.000 | 15.000 | 7.000 | 10.000 | |
| 219 | is exterior? (fully or partially) | D _{mm} | mm | 100 | 75 | 50 | 23 | 61.6 |
| 221 | min temperature this stage | boolean | 1 | 1 | 1 | 1 | 1 | 1 |
| 222 | air stream temperature relative to the local dewpoint | T _{min} = min(T ₁ , T ₂) | °C | 2.7 | 3.0 | 1.6 | 3.7 | 14.2 |
| 223 | temperature difference needing insulation | ΔT _d = T _{min} - select(T _d) | °C | -10.3 | -10.0 | -11.4 | -9.3 | 1.2 |
| 224 | temperature diff from a condensing surface to local ambient | ΔT _{insul} = abs(min(0, ΔT _{insul})) | °C | 10.3 | 10.0 | 11.4 | 9.3 | 0.0 |
| 225 | iterative thickness calc intermediate value | ΔT _{cond2amb} = select(T _{amb}) - select(T _d) | °C | 22.0 | 22.0 | 22.0 | 22.0 | 22.0 |
| 226 | insulation minimum outside diameter (neglects pipe wall) | λ = k * ΔT _{insul} / (h _{insul} * ΔT _{cond2amb}) | mm | 1.9 | 1.8 | 2.1 | 1.7 | 0.0 |
| 227 | insulation minimum thickness (no margin) | D _{min} = 2 * λ / ln(D _{insul} / D) | mm | 104.4 | 80.6 | 54.0 | 26.2 | 67.8 |
| 228 | insulation design thickness | t _{min} _{insul} | mm | 2.2 | 2.8 | 2.0 | 1.6 | 3.1 |
| 229 | pipe + insulation outer diameter (pipe wall neglected) | t _{insul} = t _{design_factor} * t _{min} _{insul} | mm | 4.4 | 5.6 | 4.0 | 3.2 | 6.2 |
| | | D _{total_no_wall} | mm | 108.8 | 86.1 | 58.0 | 29.4 | 73.9 |


Services

- SVT
 - IB services are primarily in forward region,
 - OB and disk services are evenly split between forward and backward region,
 - Cross section needs for power dominate over signal by an order of magnitude,
 - Power conductor size driven by voltage drop; lower gauge (thicker conductors) between disconnect and racks,
 - **Services include cooling air outlets, as well as all inlets, and liquid lines.**

Backward region

| Subsystem | Type | Item | Material | Cable Specifics | Quantity | Diameter (cm) | Cross Area (cm ²) | Notes |
|-------------------------|---------|-------------------------|-----------------------|------------------------|----------|---------------|-------------------------------|--|
| Inner Barrel | Power | LV | Multi-Conductor Cable | 4 Al conductors, 18AWG | 16 | 0.9 | NA | All on the hadron side; none on the electron side |
| | Signal | Data | 144 Fiber Cable | | 4 | 0.89 | NA | All on the hadron side; none on the electron side; harnesses TBD |
| | Cooling | cooling | Air | | 2 | 2.54 | NA | All on the hadron side; none on the electron side |
| | Cooling | Exhaust | Air | | | | 40.54 | Preliminary estimate, not subject to packing & misc. |
| Outer Barrel | Power | LV | Multi-Conductor Cable | 4 Al conductors, 18AWG | 93 | 0.9 | 59.16 | |
| | Signal | Data | 144 Fiber Cable | | 6 | 0.89 | 3.73 | |
| | Cooling | cooling | Air | | 8 | 2.54 | 40.54 | |
| | Cooling | Exhaust | Air | | | | 162.15 | Preliminary estimate, not subject to packing & misc. |
| Disks | Power | LV | Multi-Conductor Cable | 4 Al conductors, 18AWG | 185 | 0.9 | 117.69 | |
| | Signal | Data | 144 Fiber Cable | | 12 | 0.89 | 7.47 | |
| | Cooling | Cooling | Air | | 10 | 2.54 | 50.65 | |
| | Cooling | Exhaust | Air | | | | 202.60 | Preliminary estimate, not subject to packing & misc. |
| Outer Barrel / Disks FB | Signal | Read out Fibers | | | | NA | NA | part of the fiber counts above (OB, disks) insofar external |
| | Power | Ext Current Source | | | | NA | NA | powered by CB (i.e. internal services, but not external) |
| | Cooling | cooling | Air / convection | | | NA | NA | XTRx+ can be cooled convectively per its manual |
| Outer Barrel / Disks CB | Signal | Slow Control Fibers FB | 144 Fiber Cable | | 1 | 0.89 | 0.62 | |
| | Signal | Slow Control Fibers FPC | 144 Fiber Cable | | 1 | 0.89 | 0.62 | |
| | Power | Ext Voltage Source | | 4 Al conductors, 18AWG | 26 | 0.9 | 16.54 | 16 OB control boards, 36 disk control boards |
| | Cooling | Cooling | Water | | 28 | 0.63 | 8.73 | Approx. 1.3 kW to be cooled |
| Inner Barrel SCB | Signal | Control Fibers | 144 Fiber Cable | | 1 | 0.89 | NA | All on the hadron side; none on the electron side; harnesses TBD |
| | Cooling | Cooling | Water | | 4 | 0.63 | NA | All on the hadron side; none on the electron side |
| Inner Barrel DPB | Signal | Control Fiber | 144 Fiber Cable | | 1 | 0.89 | NA | All on the hadron side; none on the electron side; harnesses TBD |
| | Power | Bulk Power | Multi-Conductor Cable | 4 Al conductors, 18AWG | 16 | 0.9 | NA | All on the hadron side; none on the electron side |
| | Cooling | Cooling | Water | | 4 | 0.63 | NA | All on the hadron side; none on the electron side |
| Ground(s) | | | | | | | 0.70 | Preliminary estimate |
| Interlocks | | | | | | | 4.00 | Preliminary estimate; more of a "space allocation" |
| Environmental sensors | | | | | | | 4.00 | Preliminary estimate; more of a "space allocation" |
| | | | | | | | TOTAL X1.5 | 876.97 |
| | | | | | | | | Exhaust not 1.5x, only 1.0x |

Cooling – Liquid (RDOs)



Mass needs to be minimized within the SVT envelope – “modified chilled water.”

Summary

- SVT cooling
 - based on up-to-date knowledge of continuing sensor and ancillary ASIC development,
 - system design incorporates heat transfer tests and analyses of layers, staves, and disks,
 - plant design and specifications developed, including humidity management,
 - to be done:
 - CFD analyses of the SVT internal volume in its entirety,
 - moisture effusion at close-outs as services are finalized,
 - adjustments, as needed, towards final sensor and ancillary ASIC designs,
 - complete layout in CAD of liquid cooling loops for RDOs (mainly control boards)
 - (incorporate external heat in-/out-flux)